

## SPECIFICATION

<b>Model</b>	<b>DS-K2210 Master Elevator Controller</b>
<b>Processor</b>	32 bit
<b>Communication</b>	TCP/IP;RS-485, and Wiegand
<b>Normal Card/Event</b>	20,000 Cards and 50,000 Events
<b>Indicator</b>	Power On: Solid Green Running Properly: Flashing Green Running Exception: Solid Red Serial Port Not Communicating: Off Serial Port Communicating: Solid Green Relay NC: Off Relay NO: Solid Green Network Disconnected: Off Network Cable Connected: Solid Yellow, Flashing Green Network Armed: Solid Yellow, Flashing Green
<b>Internal Clock</b>	Support
<b>Card Reader</b>	Up to 2 RS-485 Card Readers or 2 Wiegand Card Readers
<b>Input Interface</b>	1 Panic Button; 1 Fire Alarm Button; 1 Maintenance Button
<b>Output Interface</b>	5 Relay Outputs
<b>RTC</b>	Support
<b>Power Supply</b>	12 VDC±15%
<b>Working Temperature</b>	-40°F to 158°F
<b>Working Humidity</b>	0% to 90% (No Condensation)
<b>Dimensions</b>	167(L)mm*105(W)mm*30(H)mm
<b>Installation Type</b>	Guide Rail Installation